


# **EXIT EMERGENCY LIGHTING**

LCDJ-SL0019







## SPECIFICATION/DESCRIPTION:

LED Emergency Sign Light: maintained working mode, configured with driver, provide battery charge and discharge, with DALI-2 function or individual auto-test function

INPUT VOLTAGE:220-240AC 50/60Hz	EFFICACY:130Lm/W(LED)
LUMINOUS BODY: 3MM light guide plate	LUMINANCE:55 2cd/
PATTERN BOARD: 1.0mm PMMA (it can be replaced)	WARRANTY:3Years

#### **AUTO TEST FEATURES**

Performs 20 second functional test every 30days

Rated duration test every 52 weeks in accordance with EN 50172:2004

The product will automatically choose one random date from 1-30 days as base date for calculating the rated duration test date.

Indication through a bi-colour LED

### **STANDARD**

DALI-2 No.6255 (LC-ZD001),

DALI-2 protocol: 101 102 202 104 250 251 252 253 254


Certificate: CB, CE, EMC

## **INSTALLATION:**

Using 86 type switch box and cooperative with the installation of emergency electrical box(available in round and square), beautiful and convenient.

The pattern indicator board is use slot plug-in emergency electrical box base.

 $According \ to \ user's \ needs, four \ kinds \ of \ indicator \ board \ can \ be \ replaced \ flexibly \ accordingly.$ 



Besteil-Nr	Type No	light	Battery	Display	Duration	Function	Packing	Qty Weight
41303190	LCDJ-SL0019	0.5/1W	6.4v0.5Ah LiFePO4	Single	3.0H	Autotest	450X450X100	20Pcs 8Kg
42303190	LCDJ-SL0019-D	0.5/1W	6.4v0.5Ah LiFePO4	Single	3.0H	DALI-2	450X450X100	20Pcs 8Kg